



THE SERVICE LINE MAY EXIT THE HOUSE ABOVE THE BASEMENT FLOOR BUT A MINIMUM COVER OF 3'-6" MUST BE MAINTAINED

ELEVATION
SANITARY SEWER SERVICE LINE

FURNISHED & INSTALLED BY THE BOROUGH ——— FURNISHED & INSTALLED BY THE PROPERTY OWNER

NOTES:

- ① The septic tank MUST be by-passed. No connection of any type through the tank is permitted in a municipal sewer system.
- ② The service line shall be P.V.C. (plastic) sewer pipe schedule 35 or greater. Other as approved by the Borough.
- ③ NO storm water, rain water, roof downspouts, french drains, or ground water connections of any type are permitted in the sanitary sewer system.
- ④ NO service line pipe shall have a curve exceeding 45 degrees.
- ⑤ If the service line exceeds 150 feet in length cleanouts shall be installed every 100 feet.
- ⑥ All connections must be inspected by the Borough before backfilling.
- ⑦ The house plumbing should include system vents and traps.
- ⑧ Use material free of large stone (Those over 2") when backfilling.

CONNOQUENESSING BOROUGH - SANITARY SEWER TAP
TYPICAL DOMESTIC INSTALLATION DETAIL
Connoquenessing Borough, Butler County, PA

Gray - Warnick
Engineering

682 West New Castle Road (Rt. 422) Butler, PA 16001
PA (724) 237-1088 Fax (724) 237-1104 Email: gwarnick@comcast.net

Date: FEB. 14, 2001 * Scale: NONE * By: JES Project #99512B